

Irradiation of the Optical Transmitters Test Results

Yunpeng Bai

Physik Department E18 - Technische Universität München

19th International Workshop on
DEPFET Detectors and Applications
10-13 May, 2015. Kloster Seeon

supported by:
Heinz Maier-Leibnitz Zentrum
Cluster of Excellence: Origin and Structure of the Universe,
BMBF



Hardware and Firmware for the Tests

Neutron Irradiation Test

Gamma Irradiation Test

Summary & Outlook



1. Glenair 050-301

850nm, 1.25Gbps

3.3V, 300mW Power consumption

Size 24x8x8 (mm)

TX (with blue stripe)



2. Avago AFBR-811FN1Z


12 channels, 850nm, 10Gbps per channel

3.3V, 2.5V; 100mW per channel


Size 22x19x15 (mm)




75x60 mm



110x110 mm





1. Data Handling Card

- AMC form factor with Xilinx Virtex 6
- Installed on the 6U standard carrier card

2. Cables between DHC and DUT

- Data transmitted using the SFP passive copper cable to DUT
- Data received via optical cable from DUT
- I2C lines for the device control

3. Irradiation Environment


- Neutron at NECTAR in FRM II, TUM Garching: $2.3 \cdot 10^8 \text{ cm}^{-2} \text{ s}^{-1}$
- Gamma ray from Co^{60} at Helmholtz Centre Munich,
I: 1.33 Gy min^{-1}
II: 9 Gy min^{-1}

1. Aurora Simplex Protocol

- 125Mhz reference clock
- 2 Gbps with 8b10b coding
- Back channel with sideband signal

2. Error counter at the receiving side

- Link down counter
- Soft error counter
 - 1) Corrupted data is not valid in 8b/10b table
 - 2) Corrupted data is in the table but has the disparity error
- Data error counter





Hardware and Firmware for the Tests

Neutron Irradiation Test

Gamma Irradiation Test

Summary & Outlook



- Neutron fluence in Belle II from the simulation

$$\text{Rate1} = 1.25 \cdot 10^{11} \text{ cm}^{-2} \text{ year}^{-1}$$

So, the 10 years' dose is

$$\text{Dose} = 12.5 \cdot 10^{11} \text{ cm}^{-2}$$



- Neutron rate at NECTAR in FRM II

$$\text{Rate2} = 2.3 \cdot 10^8 \text{ cm}^{-2} \text{ s}^{-1}$$

So, the equivalent irradiation time of the 10 years' dose is



$$\text{Exposure time} = \text{Dose}/\text{Rate2}$$

$$= 5435 \text{ s}$$



Avago AFBR-811FN1Z

- Device is 40cm away from the neutron output
- The neutron source slot variable up to 30x20 cm





- Irradiating results

Increasing the dose step by step


1. 13 seconds are the system time for neutron to reach the slot

	Dose(neutron/cm⁻²)	Time(s) + 13s¹	Accumulated Dose	Errors
Step 1	$5 \cdot 10^{10}$	217 + 13	$5 \cdot 10^{10}$	No
Step 2	$5 \cdot 10^{10}$	217 + 13	$10 \cdot 10^{10}$	No
Step 3	$10 \cdot 10^{10}$	434 + 13	$20 \cdot 10^{10}$	No
Step 4	$10 \cdot 10^{10}$	434 + 13	$30 \cdot 10^{10}$	No
Step 5	$20 \cdot 10^{10}$	868 + 13	$50 \cdot 10^{10}$	No
Step 6	$75 \cdot 10^{10}$	3265 + 13	$125 \cdot 10^{10}$	No
Step 7	$125 \cdot 10^{10}$	5435 + 13	$250 \cdot 10^{10}$	No


- Step 7 is the 10 years' equivalent dose of neutrons
- Total dose is equivalent to 20 years



- The neutron source slot



- Connections





- Irradiating results

Increasing the dose step by step

	Dose(neutron/cm⁻²)	Time(s) + 13s¹	Accumulated Dose	Errors
Step 1	$62.5 \cdot 10^{10}$	2718 + 13	$62.5 \cdot 10^{10}$	No
Step 2	$62.5 \cdot 10^{10}$	2718 + 13	$125 \cdot 10^{10}$	No
Step 3	$125 \cdot 10^{10}$	5435 + 13	$250 \cdot 10^{10}$	No

Total dose is equivalent to 20 years'

Hardware and Firmware for the Tests

Neutron Irradiation Test



Gamma Irradiation Test

Summary & Outlook



Gammacell 220 I / II

- Nuclide: Cobalt-60
- Closed unit irradiation chamber
- Size: height 20,6cm; \varnothing 15,2 cm
- Homogeneous value in the centre 4x5 cm





Setup

- Align the test device in the centre of the chamber
- All the cables are guided outside through the hollow cylinder



Gammacell I strength

- In April: **1,33 Gy min⁻¹**

radiationzentrum münchen
Deutsches Forschungszentrum für Gesundheit und Umwelt

DL - Werte an der *Gammacell I* im Jahr 2015

Co⁶⁰; T_{1/2} = 5.27 a

(Bei Verwendung des Ausgleichsfilters gelten die *halben* Werte)

Bestrahlungs- geometrie	sehr kleine H ₂ O - Menge Gy min ⁻¹	kl. H ₂ O - Menge im Temp. Becher Gy min ⁻¹	ca. 100 ml H ₂ O im Tem. Becher Gy min ⁻¹	0,5 - 1,0 l H ₂ O Gy min ⁻¹
Monat				
Januar	1,37	1,30	1,24	1,17
Februar	1,36	1,28	1,22	1,16
März	1,35	1,27	1,21	1,14
April	1,33	1,26	1,20	1,13
Mai	1,32	1,24	1,18	1,12
Juni	1,30	1,23	1,17	1,11
Juli	1,29	1,22	1,16	1,09
August	1,27	1,20	1,15	1,08
September	1,26	1,19	1,13	1,07
Oktober	1,25	1,18	1,12	1,06
November	1,23	1,16	1,11	1,05
Dezember	1,22	1,15	1,10	1,04



Gammacell I, Avago AFBR 811FN1Z

- Belle II 20 years' equivalent dose
Dose = 200 krad
 - Gammacell I rate
Rate = 1,33 Gy/min = 133 Rad/min
- ⇒ So, the equivalent irradiation time is
Exposure time = Dose/Rate = 1534 min

1. At beginning in Gammacell I

- Two channels are working
- 3.3V has 138mA current
- 2.5V has 176mA current
- I2C working

2. Power Cycle after step2 completed

- Two channels are not working
- 3.3V has 114mA current
- 2.5V has 47mA current
- I2C gets wrong value

	Dose(krad)	Time(min)	Accumulated Dose(krad)	Status
Step 1	9.3	70	9.3	✓
Step 2	125.6	944	134.9	
	67.3	506	76.6	No Data Err, but both link are down, I2C gets wrong value



Setup is the same as that in Gammacell I

- A new Avago AFBR-811FN1Z into it
- Gammacell II rate in April:

$$\text{Rate} = 9 \text{ Gy min}^{-1}$$

So, the equivalent
irradiation time is

$$\text{Exposure time} = \text{Dose}/\text{Rate}$$

$$= 200\text{krad}/900\text{rad min}^{-1}$$

$$= 222 \text{ min}$$

HelmholtzZentrum münchen
Deutsches Forschungszentrum für Gesundheit und Umwelt

DL - Werte an der *Gammacell II* im Jahr 2015
 Co^{60} ; $T_{1/2} = 5.27 \text{ a}$
(Bei Verwendung des Ausgleichsfilters gelten die *halben* Werte)

Bestrahlungs- geometrie	sehr kleine H ₂ O - Menge Gy min ⁻¹	kl. H ₂ O - Menge im Temp. Becher Gy min ⁻¹	ca. 100 ml H ₂ O im Temp. Becher Gy min ⁻¹	0.5 - 1.0 l H ₂ O Gy min ⁻¹
Monat				
Januar	9,30	8,78	8,37	7,90
Februar	9,19	8,68	8,27	7,82
März	9,10	8,59	8,19	7,74
April	9,00	8,50	8,10	7,65
Mai	8,90	8,41	8,01	7,57
Juni	8,81	8,31	7,92	7,48
Juli	8,71	8,22	7,84	7,40
August	8,61	8,13	7,75	7,32
September	8,52	8,04	7,67	7,24
Oktober	8,43	7,96	7,58	7,16
November	8,33	7,87	7,50	7,08
Dezember	8,24	7,78	7,42	7,00



Results Avago 811FN1Z in Gammacell II

	Dose(krad)	Time(min)	Accumulated Dose(krad)	Status
Step 1	108	120	108	
	98.1	109	98.1	No Data Err, but both link are down, I2C gets wrong value

1. At beginning in Gammacell II

- Two channels are working
- 3.3V has 129mA current
- 2.5V has 172mA current
- I2C works well

2. Before Power Cycle

- Two channels do not work anymore
- 3.3V has 145mA current
- 2.5V has 175mA current
- I2C gets wrong value

3. After Power Cycle

- Two channels still do not work
- 3.3V has 110mA current
- 2.5V has 51mA current
- I2C gets wrong value




Setup

- The test device in the centre of the **Gammacell II** chamber
- All the cables are guided outside through the hollow cylinder

Gammacell II centre strength

- In April: 9 Gy min^{-1}





Experiment in Gammacell II

	Dose(krad)	Time(min)	Accumulated Dose(krad)	Status
Step 1	168.3	187	168.3	✓

- Two devices, one Tx, one Rx
- 3.3V has 153mA current at the beginning
- 3.3V has 155mA current in the end
- After power cycle 7, there is one single event upset in the transmitting channel

Power Cycle Steps

	Time	State
1	11:40	OK
2	11:55	OK
3	12:10	OK
4	12:25	OK
5	12:40	OK
6	12:55	OK
7	13:25	OK
8	13:55	OK
9	14:25	OK
10	14:45	OK



Hardware and Firmware for the Tests

Neutron Irradiation Test

Gamma Irradiation Test

Summary & Outlook



1. Device under neutron irradiation within the Belle II requirement

- Avago AFBR-811FN1Z: no error, working stably
- Glenair 050-301: no error, working stably

2. Device under Gamma irradiation within the Belle II requirement

- Avago AFBR-811FN1Z: stop working after the dose reach:
76.6krad(I) \approx 7.5 years
91.1krad(II) \approx 9 years
- Glenair 050-301:
Only 1 SEU during the whole period
Total dose 168.1krad


3. Reason for the damages of the Avago device under Gamma irradiation


- Corruption of the configuration memory
- We are contacting the company to check if we could program the device memory

Outlook


- Avago AFBR-811FN1Z has a problem during the Gamma irradiation
 - ASAP we get feedback from Avago, further study on this device
- Glenair 050-301 has good performance during both tests
 - Increasing the dose upto Megarad

Thank You for Your Attention!





DUT is 40cm away from the neutron output slot





Data handling card is in the second chamber behind the concrete wall

